

PROFIBUS GSD-Files depending on electronic key

i-matic / i-maticC

xiMxxx-xx-AB-xxx

xiMCxxx-xx-AB-xxx

1) PROFIsafe not available for iMC (i-maticC)

v A v	B >	1	2	3	4	5
D	DREM0825_1	DREM0825_1	DREM0825_1	DREM0825_1	DREM0824_1	
E	DREM0825_1	DREM0825_1	DREM0825_1	DREM0825_1	DREM0824_1	
H	DREM0825_1	DREM0825_1	DREM0825_1	DREM0825_1	DREM0824_1	
K	DR070825_1	DR070825_1	DR070825_1	DR070825_1		x
L	DR070825_1	DR070825_1	DR070825_1	DR070825_1		x

1)
1)

Attention:

When a single line actuator (DREM0825_1) is connected to a redundant Network using a Y-Link Device the GSD-File DR010825_1 must be used instead!

Matic C

xCxxx-xxxx-ABCD-xxx

v AB v	CD >	xx	30	40	50
OP	EMGD0686		x	x	x
OD		x	DR020C27	DR020C27	DR020C26
OE		x	DR020C27	DR020C27	DR020C26
OF		x	x	DR020C27	DR020C26